



**AHMEDABAD MUNICIPAL CORPORATION**  
**FIRE AND EMERGENCY SERVICES DEPARTMENT**

DANAPITH FIRE STATION (HEADQUARTERS), NR.AMC OFFICE, DANAPITH, AHMEDABAD

NOC Number: NOC227926072021

Category: School

NOC Issue Date: 06/08/2021

**NO OBJECTION CERTIFICATE**

This is to certify that management of M/s **KENDRIYA VIDYALAYA NO.1 AHMEDABAD** located at **MR CAMPUS, SHAHIBAUG NEAR POLICE COMMISSIONER'S OFFICE, GUJARAT 380004** has installed necessary Fire Protection Equipments mentioned below.

**Hydrant System With**

- \* Main Pump - ( 1 Nos.)
- \* Fire Bridge Inlet (2/4 Way) - ( 1 Nos.)
- \* Hose Reel - ( 9 Nos.)
- \* Manual Call Point - ( 8 Nos.)
- \* Fire Alarm System Installed Yes

**Fire Extinguishers**

- \* 6 Kg. Capacity ABC Type - ( 16 Nos.)
- \* 4.5 Kg. Capacity Co2 Type - ( 6 Nos.)

All the Fire Protection Equipments installed shall be maintained in working order throughout the validity period of this certificate.

**This Certificate is valid for THREE YEAR from the date of issue.**



(Rajesh Bhatt)  
Chief Fire Officer (I/c)  
Ahmedabad Municipal Corporation